

§ 112.15-5

46 CFR Ch. I (10-1-12 Edition)

(f) At least one light in each space where a person may be maintaining, repairing, or operating equipment, stowing or drawing stores or equipment, or transiting, such as public spaces, work spaces, machinery spaces, workshops, galleys, emergency fire pumprooms, bow thruster rooms, storage areas for paint, rope, and other stores, underdeck passageways in cargo areas, steering gear rooms, windlass rooms, normally accessible duct keels with valve operators, cargo handling rooms, and holds of roll-on/roll-off vessels.

(g) Lighting for survival craft launching, including muster stations, embarkation stations, the survival craft, its launching appliances and the area of the water where it is to be launched.

(h) Electric communication systems that are necessary under temporary emergency conditions and that do not have an independent storage battery source of power.

(i) Each power operated watertight door system.

(j) All shipwide communications systems necessary for the transmittal of information during an emergency.

(k) Each fire door holding and release system.

(l) Supply to motor generator or other conversion equipment if a temporary emergency power source of alternating current is necessary for essential communication systems or emergency equipment.

(m) Each daylight signaling light.

(n) Each smoke detector system.

(o) Each electrically controlled or powered ship's whistle.

(p) Each fire detection system; and gas detection system if installed.

(q) All lighting relative to helicopter operations and landing if installed, unless provided for by another source of power (such as independent batteries separately charged by solar cells).

(r) Each general emergency alarm system required by IMO SOLAS 74 (incorporated by reference; see 46 CFR 110.10-1).

[CGD 74-125A, 47 FR 15267, Apr. 8, 1982, as amended by CGD 94-108, 61 FR 28286, June 4, 1996; USCG-2003-16630, 73 FR 65201, Oct. 31, 2008]

§ 112.15-5 Final emergency loads.

On vessels required to have a final emergency power source by § 112.05-5(a) of this chapter, the following emergency lighting and power loads must be arranged so that they can be energized from the final emergency power source:

(a) Each load under § 112.15-1.

(b) The machinery, controls, and alarms for each passenger elevator.

(c) Each charging panel for:

(1) Temporary emergency batteries;

(2) Starting batteries for diesel engines or gas turbines that drive emergency generators; and

(3) General alarm batteries.

(d) One of the bilge pumps, if the emergency power source is its source of power to meet Part 56 of this chapter.

(e) One of the fire pumps, if the emergency power source is its source of power to meet the requirements of the subchapter under which the vessel is certificated.

(f) Each sprinkler system, water spray extinguishing system, or foam system pump.

(g) If necessary, the lube oil pump for each propulsion turbine and reduction gear, propulsion diesel reduction gear, and ship's service generator turbine which needs external lubrication.

(h) Each rudder angle indicator.

(i) Each radio or global maritime distress and safety system (GMDSS) component.

(j) Each radio direction finder, radar, gyrocompass, depth sounder, global positioning system (GPS), satellite navigation system (SATNAV), speed log, rate-of-turn indicator and propeller pitch indicator.

(k) Each steering gear feeder, if required by part 58, subpart 58.25, of this chapter.

(l) Each general emergency alarm flashing light required by § 113.25-10 of this chapter.

(m) Each electric blow-out-preventer control system.

(n) Any permanently installed diving equipment that is dependent upon the vessel's or drilling unit's power.

(o) Each emergency generator starting compressor, as allowed by § 112.50-7(c)(3)(ii).

(p) Each steering gear failure alarm required by part 113, subpart 113.43, of this chapter.

(q) The ballast control system on each column-stabilized mobile offshore drilling unit.

(r) Each vital system automation load required by part 62 of this chapter.

(s) Motor-operated valves for each cargo oil and fuel oil system, if the emergency power source is the source of power to meet § 56.60(d) of this chapter.

(t) Each ship's stabilizer wing, unless a separate source of emergency power is supplied.

(u) Each indicator that shows the position of the stabilizer wings, if the emergency power source is its emergency source of power.

(v) Each smoke extraction fan, not including smoke detector sampling, and carbon dioxide or clean agent exhaust fans for spaces.

[CGD 74-125A, 47 FR 15267, Apr. 8, 1982, as amended by CGD 94-108, 61 FR 28287, June 4, 1996; 61 FR 36787, July 12, 1996; USCG-2010-0759, 75 FR 60003, Sept. 29, 2010; USCG-2006-24797, 77 FR 33882, Jun. 7, 2012]

§ 112.15-10 Loads on systems without a temporary emergency power source.

If there is no temporary emergency power source, the loads under § 112.15-1 must be arranged so that they can be energized from the final emergency power source.

Subpart 112.20—Emergency Systems Having a Temporary and a Final Emergency Power Source

§ 112.20-1 General.

This subpart contains requirements applicable to emergency power installations having both a temporary and a final emergency power source.

§ 112.20-3 Normal source for emergency loads.

(a) The normal source for emergency loads must be the ship's service generating plant.

(b) The power from the ship's service generating plant for the emergency loads must be supplied to the emergency switchboard through automatic transfer switches.

§ 112.20-5 Failure of power from the normal source or final emergency power source.

(a) If there is a reduction of potential of the normal source by 15 to 40 percent, the loads under § 112.15-1 must be automatically supplied from the temporary emergency power source.

(b) For systems in which a reduction of frequency of the normal source or final emergency power source adversely affects the emergency system and emergency loads, there must be means to transfer the loads under § 112.15-1 to the temporary emergency power source upon a reduction in the frequency of the normal source or final emergency power source.

§ 112.20-10 Diesel or gas turbine driven emergency power source.

Simultaneously with the operation of the transfer means under § 112.20-5, the diesel engine or gas turbine driving the final emergency power source must start automatically with no load on the final emergency power source.

§ 112.20-15 Transfer of emergency loads.

(a) When the potential of the final emergency power source reaches 85 to 95 percent of normal value, the emergency loads under § 112.15-5 must transfer automatically to the final emergency power source and, on a passenger vessel, this transfer must be accomplished in no more than 45 seconds after failure of the normal source of power.

(b) When the potential from the normal source has been restored, the emergency loads must be manually or automatically transferred to the normal source, and the final emergency power source must be manually or automatically stopped.

(c) If the potential of the final emergency power source is less than 75 to 85 percent of normal value while supplying the emergency loads, the temporary emergency loads under § 112.15-1 must transfer automatically to the temporary emergency power source.